

Ulysses Water District No.3 NY5430047

Disinfection By Products Sampling Results									
	Cayuga Medical	Woolf La.	Hyd. 1 Rt 96/Iradell Rd	van Dorn or JacksonvilleTan k	Hyd. 48 Perry City/J-ville	Hyd. 18 Perry City/Rt 96	Hyd 28 96 & J-ville Rd	Hydrant 60 or 58 Jacksonville Rd	Hyd 74 Cold Springs Rd
	Total Trihalomethanes (TTHM) ppb (parts per billion)								
Sample Date	*Levels exceeding the federal limit (80ppb) are shown in red .								
3/7/2010								41	
8/11/2010								96.8	
11/3/2010								63.6	
2/23/2011								42.1	
6/15/2011								80	
8/10/2011								71	
10/19/2011								96.8	
3/7/2012								55.2	
5/9/2012								74.5	
8/22/2012								104.1	
12/20/2012								61.6	
3/27/2013								63	
6/12/2013								91.8	
8/7/2013		52						104	
10/9/2013		100							
10/16/2013								105	
11/6/2013		64						74.6	
1/15/2014								77.5	
4/9/2014		44						62	
4/16/2014					42				
5/8/2014								64	
7/23/2014								94	
9/10/2014				97			106	108	100
10/8/2014		68		88			96	105	100
11/5/2014	62	82	81	88	106	90	114	115	128
12/10/2014	60	59	59	58	73	52	76	78	88
1/7/2015	42	43	43	55	48	53	62	64	68
3/4/2015	35	40	38	47	48	41	48	49	56
4/8/2015								52	
5/6/2015	44	44	52	60	60	56	62	65	60
7/8/2015	66	64	64	101	88	86	104	123	117
9/8/2015	68	74	81	111	89	106	110	114	113
10/7/2015		71						124	
11/4/2015	48	57	59	70	73	70	78	87	87
12/9/2015								80	
1/6/2016	48	54	53	63	67	65	68	81	83
3/9/2016	57	57	58	64	61	64	62	73	74