

Ulysses Water District No.3 NY5430047

Disinfection ByProducts Sampling Results

	Total Haloacetic Acids (HAAs)	MCL + 60 ug/l	Total Trihalomethanes (TTHM)	MCL + 80 ug/l
Sample Date	Level (ug/l)	Running Annual Average (ug/l)	Level (ug/l)	Running Annual Average (ug/l)
3/7/2010	29.3		41	
8/11/2010	28		96.8	
11/3/2010	24.4	26.20	63.6	80.20
2/23/2011	21	25.68	42.1	60.88
6/15/2011	40	28.35	80	70.63
8/10/2011	34	29.85	71	64.18
10/19/2011	16.2	27.80	96.8	72.48
3/7/2012	30	30.05	55.2	75.75
5/9/2012	32.5	28.18	74.5	74.38
8/22/2012	14	23.18	104.1	82.65
12/20/2012	29.2	26.43	61.6	73.85
3/27/2013	30	26.43	63	75.80
6/12/2013	27.9	25.28	91.8	80.13
8/7/2013	25.41	28.13	104	80.10
10/16/2013	14.9	24.55	105	90.95
1/15/2014	16.4	21.15	77.5	94.58
4/9/2014	26	20.68	62	87.13
7/23/2014	31	22.08	94	84.63
10/8/2014	28	25.35	105	84.63
1/7/2015	31	29.00	64	81.25
4/8/2015	28	29.50	52	78.75